


Evaluation ENERBUILD-Tool – existing buildings

EWZ Zermatt



[Pictures from Lauber IWISA AG]

1 Basic information about the building

| | |
|--|--|
| Name of the building | Verwaltungsgebäude EWZ Zermatt |
| Address of the building | Metzggasse 44, CH-3920 Zermatt |
| Owner/investor | Elektrizitätswerk Zermatt AG (Electric Power Company) |
| Year of construction | 2004-2005 |
| Building type | New administration building with school/ class rooms at 1'631m a.s.l. |
| Building method | Massive construction with wooden cladding |
| Number of buildings | 1 |
| Number of levels above earth | 5 |
| Number of levels underground | - |
| Kind of the public use | Administrative and school building |
| Effective area for public use in m ² (net) | 1'852 m ² |
| Additional private uses | - |
| Effective area for private use in m ² (net) | - |
| Total effective area in m ² | 1'852 m ² |
| Source of energy for heating | Electrical heat pump with air ventilation recovery system with additional solar collectors |
| Heating system | As before; additional PV elements contribute to the coverage of the power consumption |
| Water heating system | |
| Date of the building evaluation | 2010/2011 |

2 Execution of the building evaluation with the ENERBUILD tool

Responsible Organisation: Lucerne University of Applied Sciences and Arts – Lucerne School of Engineering and Architecture – Competence Center Topology & Foresight Planning in Architecture, Technikumstrasse 21, CH-6048 Horw Contact person: C.Lars Schuchert

Telephone: +41 41 349 34 96 Email: lars.schuchert@hslu.ch

Temperature for thermal comfort in summertime: 25°C

Local limits for heating demand: in Switzerland, the local limit for the heating demand is determined by the building's location (mean annual temperature), the building surface-to-heated floor area ratio, and its use. Also the limit differs according to the energy standard. Since the treaded floor area is calculated differently and the basic data is also taken into account differently, the values cannot be directly compared to the values of the calculation via PHPP. (The calculation according to Minergie(-P) standard usually achieve lower values (refer to: Zentrum für Energie und Nachhaltigkeit im Bauwesen. Minergie und Passivhaus: Zwei Gebäudestandards im Vergleich – Schlussbericht. 2002. Page 6)

The limits for this administration building are:




New building, administration: 60 kWh/m²a (according to SIA 380/1:2001, converted from 217 MJ/m²)

3 Results

| Nr. | Title | Must criteria (M) | max. points | evaluated points |
|------------|--|-------------------|------------------|------------------|
| A | Quality of location and facilities | | max. 100 | 62 |
| A 1 | Access to public transport network | | 50 | 12 |
| A 2 | Ecological quality of site | | 50 | 50 |
| B | Process and planning quality | | max. 200 | 106 |
| B 1 | Decision making and determination of goals | | 25 | 16 |
| B 2 | Formulation of verifiable objectives for energetic and ecological measures | M | 20 | 20 |
| B 3 | Standardized calculation of the economic efficiency | M | 40 | 0 |
| B 4 | Product-management - Use of low-emission products | | 60 | 0 |
| B 5 | Planning support for energetic optimization | | 60 | 50 |
| B 6 | Information for users | | 25 | 20 |
| C | Energy & Utilities (Passive house) | | max. 350 | 350 |
| C 1 | Specific heating demand (PHPP) | M | 100 | 76 |
| C 2 | Specific cooling demand (PHPP) | M | 100 | 100 |
| C 3 | Primary energy demand (PHPP) | M | 125 | 125 |
| C 4 | CO ₂ -emissions (PHPP) | | 50 | 50 |
| D | Health and Comfort | | max. 250 | 65 |
| D 1 | Thermal comfort in summer | | 150 | 65 |
| D 2 | Ventilation - non energetic aspects | | 50 | n/a |
| D 3 | Daylight optimized (+ lighting optimized) | | 50 | n/a |
| E | Building materials and construction | | max. 200 | 0 |
| E 1 | OI ₃ ^{TGH-IC} ecological index of the thermal building envelope (respectively OI ₃ of the total mass of the building) | | 200 | 0 |
| Sum | | | max. 1000 | 583 |

Evaluation ENERBUILD-Tool – existing buildings

School building (with gym) Eichmatt



1 Basic information about the building

| | |
|--|---|
| Name of the building | Schulhaus Eichmatt |
| Address of the building | Eichmattstrasse 11 |
| Owner/investor | 6333 Hünenberg See |
| Year of construction | 2009 |
| Building type | New school building with gym at 400m a.s.l. |
| Building method | Wood and massive construction |
| Number of buildings | 1 |
| Number of levels above earth | 3 (the lowest levels is partially underground, ca. 25%) |
| Number of levels underground | - |
| Kind of the public use | School |
| Effective area for public use in m ² (net) | ca. 6'500 m ² |
| Additional private uses | 1 apartment |
| Effective area for private use in m ² (net) | ca. 160 m ² |
| Total effective area in m ² | ca. 6'560 m ² |
| Source of energy for heating | Thermal ground probe with electrical heat pump, mechanical ventilation with heat recovery; additional photovoltaic elements |
| Heating system | Thermal ground probe with heat pump |
| Water heating system | |
| Date of the building evaluation | 2010/2011 |

2 Execution of the building evaluation with the ENERBUILD tool

Responsible Organisation: Lucerne University of Applied Sciences and Arts – Lucerne School of Engineering and Architecture – Competence Center Topology & Foresight Planning in Architecture, Technikumstrasse 21, CH-6048 Horw; Contact person: C.Lars Schuchert

Telephone: +41 41 349 34 96

Email: lars.schuchert@hslu.ch

Temperature for thermal comfort in summertime: 26°C

Local limits for heating demand: in Switzerland, the local limit for the heating demand is determined by the building's location (mean annual temperature), the building surface-to-heated floor area ratio, and its use. Also the limit differs according to the energy standard. Since the treaded floor area is calculated differently and the basic data is also taken into account differently, the values cannot be directly compared to the values of the calculation via PHPP. (The calculation according to Minergie(-P) standard usually achieve lower values (refer to: Zentrum für Energie und Nachhaltigkeit im Bauwesen. Minergie und Passivhaus: Zwei Gebäudestandards im Vergleich – Schlussbericht. 2002. Page 6) The limits for this school building are:

New building, school: 45 kWh/m²a (according to SIA 380/1:2001, converted from 161 MJ/m²)

3 Results

| Nr. | Title | Must criteria (M) | max. points | evaluated points |
|------------|---|-------------------|------------------|------------------|
| A | Quality of location and facilities | | max. 100 | 76 |
| A 1 | Access to public transport network | | 50 | 36 |
| A 2 | Ecological quality of site | | 50 | 40 |
| B | Process and planning quality | | max. 200 | 163 |
| B 1 | Decision making and determination of goals | | 25 | 25 |
| B 2 | Formulation of verifiable objectives for energetic and ecological measures | M | 20 | 18 |
| B 3 | Standardized calculation of the economic efficiency | M | 40 | 0 |
| B 4 | Product-management - Use of low-emission products | | 60 | 50 |
| B 5 | Planning support for energetic optimization | | 60 | 55 |
| B 6 | Information for users | | 25 | 15 |
| C | Energy & Utilities (Passive house) | | max. 350 | 350 |
| C 1 | Specific heating demand (PHPP) | M | 100 | 100 |
| C 2 | Specific cooling demand (PHPP) | M | 100 | 100 |
| C 3 | Primary energy demand (PHPP) | M | 125 | 125 |
| C 4 | CO ₂ -emissions (PHPP) | | 50 | 50 |
| D | Health and Comfort | | max. 250 | 65 |
| D 1 | Thermal comfort in summer | | 150 | 65 |
| D 2 | Ventilation - non energetic aspects | | 50 | n/a |
| D 3 | Daylight optimized (+ lighting optimized) | | 50 | n/a |
| E | Building materials and construction | | max. 200 | 123 |
| E 1 | OI ₃ ^{TGH-ic} ecological index of the thermal building envelope (resp. OI ₃ of the total mass of the building) | | 200 | 123 |
| Sum | | | max. 1000 | 777 |

Evaluation ENERBUILD-Tool – Building in planning phase

Annex Wing Triemli Hospital Zürich



[Pictures from Stadt Zürich – Amt für Hochbauten]

1 Basic information about the building

| | |
|--|--|
| Name of the building | Stadtsptial Triemli – Neubau Bettenhaus |
| Address of the building | Birmensdorfer Strasse 497, CH-8063 Zürich |
| Owner/investor | Stadt Zürich, Amt für Hochbauten |
| Year of construction | 2008-2015 |
| Building type | New hospital building at 460m a.s.l. |
| Building method | Massive construction |
| Number of buildings | 1 (annex wing to existing building) |
| Number of levels above earth | 15 |
| Number of levels underground | 2 |
| Kind of the public use | City hospital |
| Effective area for public use in m ² (net) | ca. 900 m ² restaurant/ guest areas ca. 29'000 m ² patient stations |
| Additional private uses | - |
| Effective area for medical use in m ² (net) | ca. 19'400 m ² medical stations and facilities |
| Total effective area in m ² | ca. 49'300 m ² |
| Source of energy for heating | Thermal ground probe with heat pump and biomass (wood) boiler; emergency backup with gas/ oil (biomass, gas/oil backup are also supplying steam for hygienic applications) |
| Heating system | Thermal ground probe with heat pump (80%, also used for cooling) and biomass (wood) boiler (20%) |
| Water heating system | Heat pump (100%) |
| Date of the building evaluation | 2010/2011 |

2 Execution of the building evaluation with the ENERBUILD tool

Responsible Organisation: Lucerne University of Applied Sciences and Arts – Lucerne School of Engineering and Architecture – Competence Center Topology & Foresight Planning in Architecture, Technikumstrasse 21, CH-6048 Horw, Contact person: C.Lars Schuchert

Telephone: +41 41 349 34 96

Email: lars.schuchert@hslu.ch

Temperature for thermal comfort in summertime: 25°C, the standard room temperature is adjusted to 22°C for hospital buildings according to Swiss SIA 380/1:2009, 3.5.1.2.

Local limits for heating demand: in Switzerland, the local limit for the heating demand is determined by the building's location (mean annual temperature), the building surface-to-heated floor area ratio, and its use. Also the limit differs according to the energy standard. Since the treaded floor area is calculated differently and the basic data is also taken into account differently, the values cannot be directly compared to the values of the calculation via PHPP. (The calculation according to Minergie(-P) standard usually achieve lower values (refer to: Zentrum für Energie und Nachhaltigkeit im Bauwesen. Minergie und Passivhaus: Zwei Gebäudestandards im Vergleich – Schlussbericht. 2002. Page 6)

The limits for this hospital building are:

New building, hospital: 38 kWh/m²a (according to SIA 380/1:2007, converted from 136 MJ/m²)

3 Results

| Nr. | Title | Must criteria (M) | max. points | evaluated points |
|------------|--|-------------------|------------------|------------------|
| A | Quality of location and facilities | | max. 100 | 100 |
| A 1 | Access to public transport network | | 50 | 50 |
| A 2 | Ecological quality of site | | 50 | 50 |
| B | Process and planning quality | | max. 200 | 200 |
| B 1 | Decision making and determination of goals | | 25 | 25 |
| B 2 | Formulation of verifiable objectives for energetic and ecological measures | M | 20 | 20 |
| B 3 | Standardized calculation of the economic efficiency | M | 40 | 40 |
| B 4 | Product-management - Use of low-emission products | | 60 | 55 |
| B 5 | Planning support for energetic optimization | | 60 | 55 |
| B 6 | Information for users | | 25 | 25 |
| C | Energy & Utilities (Passive house) | | max. 350 | 350 |
| C 1 | Specific heating demand (PHPP) | M | 100 | 85 |
| C 2 | Specific cooling demand (PHPP) | M | 100 | 91 |
| C 3 | Primary energy demand (PHPP) | M | 125 | 125 |
| C 4 | CO ₂ -emissions (PHPP) | | 50 | 50 |
| D | Health and Comfort | | max. 250 | 225 |
| D 1 | Thermal comfort in summer | | 150 | n/a (150) |
| D 2 | Ventilation - non energetic aspects | | 50 | 25 |
| D 3 | Daylight optimized (+ lighting optimized) | | 50 | 50 |
| E | Building materials and construction | | max. 200 | 15 |
| E 1 | OI ₃ _{TGH-ic} ecological index of the thermal building envelope (respectively OI ₃ of the total mass of the building) | | 200 | 15 |
| Sum | | | max. 1000 | 890 |